

Savoy on Palm

Fire Alarm Instructions

North Units (301,401,501,601,701,801,901,1001)

The Savoy on Palm has a very advanced fire alarm system that is monitored 24/7. If the alarm becomes active for any reason, the monitoring company notifies the fire department immediately.

The fire alarm is also zoned by floors. What this means is that if the fire alarm is activated, it will set the alarm off on the active floor, one floor below, and two floors above. It will also activate in the common areas and the stairwells.

If the fire alarm is activated, and you can clearly hear the evacuation instructions inside your unit, you should proceed to the stairwell and exit the building to the outside, until the fire department has arrived. If you do not hear the voice commands to evacuate the building within your unit, it is best to stay inside your unit until the fire department has arrived. If there is a need to do a full evacuation of the building, the fire department will notify you by either the voice evacuation system, or by coming to your front door.

From your unit, the best means of evacuation is from Stairwell #1. To reach this stairwell from your unit, exit your front door and proceed through the right side door from your foyer, proceed through the other door and into the stairwell. Continue down the stairwell and it will exit at the front of the building next to the main lobby entrance.

If for any reason at all you are not able to make it down to the ground floor, wait inside the stairwell until the fire department arrives. The stairwell is a very safe place to be if there is an actual fire. There are pressurization fans in the stairwells that will activate with the fire alarm to prevent smoke from entering into the stairwells and there are no flammable building materials in the stairwells.

If for some reason you are going down the stairs and the stairs are blocked or impassable, there are crossover areas to transfer you from the front stairwell to the rear stairwell. The crossover levels are located on floors 4, 7, and 10. These stairwell and foyer doors have electric locks on them. In the event of a fire alarm activation, they will unlock until the alarm system has been reset.

If you do have to exit from the rear stairwell, please remember that it will empty out onto the third floor exterior walkway. From there you will proceed to the left corner of the building and down the exterior stairs and exit at the north east corner of the building.